

## FOOTCANDLE LIGHT GUIDE

Footcandles are the most common unit of measure used by lighting professionals to calculate light levels in businesses and outdoor spaces. A footcandle is defined as the illuminance on a one square foot surface from a uniform source of light. The Illuminating Engineering Society (IES) recommends the following footcandle levels to ensure adequate illumination and safety for occupants. Below is a guideline for common areas to assist in achieving appropriate light levels with the greatest energy-efficiency.

Building Area & Task	Average Maintained Footcandles (Horizontal) (FC)	Range of Maintained Footcandles (Horizontal) (FC)	Average Maintained Footcandles (Vertical) (FC)	Range of Maintained Footcandles (Vertical) (FC)	Comments			
WAREHOUSING & STORAGE								
Bulky Items—Large Labels	10		5					
Small Items—Small Labels	30		15					
Cold Storage	20	10 - 30	10	5 - 15				
Open Warehouse	20	10 - 30						
Warehouse w/Aisles	20	10 - 30	10	5 - 15				
COMMERCIAL OFFICE								
Open Office	40	30 - 50			@30" Above Finished Floor (AFF)			
Private Office	40	30 - 50			@30" AFF			
Conference Room	30				Matte surface reflectance for the table 40% recommended			
Restroom	18	7.5 - 30						
Lunch & Break Room	15	5 - 20						
EDUCATIONAL (SCHOOLS)								
Classroom	40	30 - 50			@30" AFF			
Gymnasium								
Class I (Pro or Div. 1 College)	125		30					
Class II (Div. 2 or 3 College)	80		20					
Class III (High School)	50		150					
Class IV (Elementary)	30		100					
Auditorium	7.5	3 - 10	5	2.5 - 10				
Corridor	25	10 - 40						

This guide is a collaborative effort of Energy Trust of Oregon and the Lighting Design Lab, Seattle, Washington.





Building Area & Task	Average Maintained Footcandles (Horizontal) (FC)	Range of Maintained Footcandles (Horizontal) (FC)	Average Maintained Footcandles (Vertical) (FC)	Range of Maintained Footcandles (Vertical) (FC)	Comments			
INDUSTRIAL/MANUFACTURING								
Assembly								
Simple (Large Item)	30	15 - 60	30	15 - 60				
Difficult (fine)	100	50 - 200	100	50 - 200				
Component Manufacturing								
Large	30	15 - 60	30	15 - 60				
Medium	50	25 - 100	50	25 - 100				
EXTERIOR								
Parking (Covered)	5				1FC min, 10:1 Max to Min Uniformity			
Parking (Open) (Medium Activity)								
Lighting Zone 3 (Urban)	1.5	.75 - 3	.8	.4 - 1.6				
Lighting Zone 2 (suburban)	1	0.5 - 2	.6	.3 - 1.2				
Gas Station Canopy	12.5	10 - 15						
Safety (Building Exterior)	1	0.5 - 2			If security is an issue— raise average level to 3			
RETAIL								
General Retail (Ambient)		50						
Department Store	40	20 - 80	15	7.5 - 30				
Perimeter			75	35 - 150				
Accent Lighting (Displays)					3 - 10 times greater than ambient light levels			
AUTOMOTIVE								
Showroom	50	25 - 100	10	5 - 20				
Service Area	50	25 - 100	30	15 - 30				
Sales Lot (Exterior)								
Lighting Zone 3 (Urban)	20	10 - 40	20	10 - 40				
Lighting Zone 2 (Suburban)	15	7.5 - 30	15	7.5 - 30				
GROCERY								
Circulation	20	10 - 40	7.5	3.5 - 15				
General Retail	50	25 - 100	20	10-40				
Perimeter			50	25-100				
BANKING								
ATM	20	10-40	15		Vertical at face of ATM			

- $\bullet \ \, \text{This guide is based on information gathered from the IES' The Lighting Handbook 10 th Edition.}$ \* Vertical—verticablanethe averagemaintained out-candle are measured lighting professional seferto the full IES guidewhen specifying lighting professional seferto the full IES guidewhen seferto the full IES gui lightingprojects.
- At least half of users are in the 25 65 agerange

- $\bullet \ \ Horizontal \underline{\hspace{0.4cm}} horizont \textbf{\textit{ap}} lane that average maintaine \textbf{\textit{d}} oot\text{-}candle \textbf{\textit{sa}} remeasured$

421 SW Oak St., Suite 300, Portland, OR 97204 **Energy Trust of Oregon** 1.866.368.7878 503.546.6862 fax energytrust.org